

Pilot Scale Membrane Bioreactor Study at King County

Amanda McInnis
Bob Bucher
Susan Anderson
J.B. Neethling



King County Water Reuse Pilot Facilities




MBR Trains



MBR Trains




- *Class A*
- *Wetlands*
- *All streams*
- *All groundwater*
- *All lakes*




- *Class A*
- *Wetlands*
- *All streams*
- *All groundwater*
- *All lakes*

Conventional Treatment



What Is a Membrane Bioreactor (MBR)?




Presentation Overview


- Study overview
- Turbidity removal
- Peaking performance
- Membrane Cleaning
- Nitrogen Removal
- Phosphorous Removal
- Coliform removal
- Operation at Low SRT



MBR 3D View




System Schematic




Pilot Study Overview

Process Goal	Actual Aerobic TSA (days)	Actual Total TSA (days)	Average Flow (gpm)	Average Flux * (gfd)	Relax mode or Backpulse mode
N/dN	--	--	5.4	11.7	Relax 8/29-9-13 Backpulse 9/14
N/dN	10.0	--	5.3	11.5	Backpulse
N/dN	10.0	15.0	7.4	16.1	Backpulse 11/16-12/2 Relax 12/3
N/dN	--	--	5.5	12.0	Relax
N/dN	5.6	8.5	5.5	12.0	Relax
N/dN	--	--	5.5	12.0	Relax
Bio-P	--	--	5.5	12.0	Relax
Bio-P	6.1	7.4	7.8	16.9	Relax

Process Overview



Turbidity Performance




Turbidity Performance

- Produced consistently low (<0.02 NTU) effluent turbidities, even under peak flow conditions.



4-hour Peaking Test




Peaking Performance

- System operated for 22 days at an avg flux of 20 gfd with effluent turbidity avg 0.02 NTU.
- The system responded well to (3) 4-hour peaking tests where flux was increased to >20 gfd.
- Effluent turbidities remained constant in the peaking tests with effluent turbidities 0.01 to 0.03 NTU.



Membrane Cleaning



Nitrogen Removal


Process Goal	Actual Total TSA (days)	Average Flux (gfd)	Effluent NH4 (mg/L)	Effluent NO3 (mg/L)
	--	11.7	0.04	6.93
N/dN	--	11.5	0.03	7.90
N/dN	15.0	16.1	0.31	5.23
N/dN	--	12.0	0.40	5.88
N/dN	8.5	12.0	0.02	7.42
N/dN	--	12.0	0.02	9.37
Bio-P	--	12.0	0.02	8.52
Bio-P	7.4	16.9	0.34	9.53

Phosphorous Removal

Process Goal	Actual Total TSA (days)	Average Flux (gfd)	Effluent TP (mg/L)	Effluent Ortho-P (mg/L)
	--	11.7	3.64	2.90
N/dN	--	11.5	1.62	1.39
N/dN	15.0	16.1	0.52	0.97
N/dN	--	12.0	0.62	0.52
N/dN	8.5	12.0	0.73	0.72
N/dN	--	12.0	1.09	1.00
Bio-P	--	12.0	0.95	0.92
Bio-P	7.4	16.9	0.97	0.92

Phosphorous Removal

- Unit was not designed for biological P removal.
- Did not meet removal goals
- No improvement in removal when process was modified for bio-P



Coliform Removal

- During Start-up, effluent total Coliform concentrations were as high as 1.7×10^3 CFU/100 mL.
- Effluent Coliform levels dropped in later phases and no Coliform was detected for the remainder of the study.



Operation at Low SRT

- The system operated successfully at a total SRT of 8 days and an aerobic SRT of 6 days for >3 months.
- The system did not have operation difficulties with high vacuum pressures



Operation at Low SRT

- Complete ammonia removal (<0.02 mg/L) was achieved
- Low effluent turbidities (0.02 NTU average) were achieved during the low SRT period.



Reverse Osmosis (RO)



- Four months of operation
- Feed trials

Reverse Osmosis (RO)

Issue	Pilot Experience
Performance	TDS < 120 mg/L (>92%) TOC < 1.6 mg/L (83%) NH4-N < 0.02 mg/L (>90%) NO3-N < 0.2 mg/L (>97.5%) TP < 0.02 mg/L (>99%) Metals < MDL
Startup	Immediate
Flux	9 gfd

Acknowledgement

- King County Technology Assessment Program
- West Point Treatment Plant Process Group
- West Point Treatment Plant Process Laboratory
- King County Environmental Laboratory
- West Point Treatment Plant O & M Staff
- King County Construction Management Staff
- HDR (Bruce Willey, JB Neethling, Michael Norton)
- B&V (Cindy Wallis-Lage)
- Zenon Environmental, Inc.



King County