



**FIRE PROTECTION NOTES:**

- FOR TRENCHING PAVEMENT RESTORATION OUTSIDE OF NEW PAVING LIMITS, SEE PROJECT NOTES ON SHEET G3 AND SECTION 5-04.3(23).
- MAINTENANCE OF TEMPORARY SURFACES: THE CONTRACTOR IS RESPONSIBLE FOR MAINTAINING TEMPORARY SURFACES UNTIL THE SURFACE HAS BEEN PERMANENTLY RESTORED. TEMPORARY SURFACES ARE TO BE MAINTAINED FLUSH WITH THE ADJACENT PAVEMENT, AT GRADE, AND IN GOOD CONDITION. TIMELY CORRECTION OF SETTLEMENT OF THE BACKFILL BENEATH THE TEMPORARY SURFACE IS THE RESPONSIBILITY OF THE CONTRACTOR. SHOULD SETTLEMENT OR OTHER FAILURE OF A TEMPORARY SURFACE OCCUR, THE CONTRACTOR SHALL QUICKLY CORRECT THE DEFECT. IF THE CONTRACTOR CANNOT QUICKLY BE NOTIFIED OR CANNOT OR DOES NOT MAINTAIN THE RESTORATION IN A TIMELY WAY, THEN SDOT MAY UNDERTAKE THE NECESSARY RESTORATION. RESTORATIONS MADE BY SDOT WILL BE BILLED TO THE CONTRACTOR AT ESTABLISHED (PUBLISHED) RATES.
- PARKING LOT SURFACE RESTORATION SHALL BE IN ACCORDANCE WITH STD PLAN NO. 404a FLEXIBLE PAVEMENT. IT WILL BE DONE AS SOON AS THE TRENCH BACKFILL IS COMPLETE. THE ASPHALT DEPTH ABOVE THE MINERAL AGGREGATE SHALL BE 2" INCHES, THIS DOES NOT INCLUDE THE OVERLAY. THE OVERLAY SHALL BE IN ADDITION TO THE 2" DEPTH SECTION.
- ALL BURIED PIPE INCLUDES POLYETHYLENE ENCASMENT (FILM WRAP).
- EXISTING POWER POLE WITH GUY ANCHORS, CONTRACTOR TO SHORE AND PROTECT. ADJUST STATIONS OF 45 DEGREE BENDS AS NECESSARY TO MAINTAIN AT LEAST 5 FEET OF CLEARANCE TO EXISTING POWER POLE.
- MAINTAIN AT LEAST 1'-6" CLEARANCE TO CB. VERIFY BEFORE LAYING PIPE. IF NECESSARY ADJUST LOCATION OF 45° BEND TO SOUTH.
- SEE SECTION 7-11.3(9)A, SERVICE CONNECTION TO EXISTING WATER MAINS FOR WORK BY CONTRACTOR.
- CALL SPU WATER SERVICES AT 206-684-5800 AND SEATTLE FIRE DEPT AT 206-386-1064 FOR WATER SERVICE AND FIRE PROTECTION INSPECTION REQUIREMENTS.
- EXISTING COMMUNICATION DUCT BANK HAS NOT BEEN LOCATED, CONTRACTOR SHALL NOTIFY ENGINEER IF 8" FP CONFLICTS WITH DUCT BANK.

**LEGEND**

ELECTROLYSIS TEST STATION  
3 WIRE

**FOR TREES TO BE PROTECTED OR RELOCATED, REFER TO LANDSCAPING PLANS**

FIRE PROTECTION PLAN-SHEET 1 FP1

<p>1601 2nd Avenue Suite 1000 Seattle, WA 98101 P: 206.441.1855   F: 206.448.7167</p> <p><b>JACOBS</b> 600 108th Avenue N.E. Bellevue, Washington 98004</p>	<p>APPROVED FOR ADVERTISING FRED PODESTA DEPARTMENT OF EXECUTIVE ADMINISTRATION SEATTLE, WASHINGTON 20</p> <p>BY: _____ DIRECTOR, CONTRACTING SERVICES</p>
---	--

<p>NAME OR INITIALS AND DATE DESIGNED: DKU 09/08 CHECKED: JMM 09/08</p> <p>DRAWN: JRE 09/08 CHECKED: DKU 09/08</p>	<p>INITIALS AND DATE REVIEWED: _____ CONST. SDOT PROJ. MGR. RECEIVED _____ REVISED AS BUILT</p>
--	---

ALL WORK DONE IN ACCORDANCE WITH THE CITY OF SEATTLE STANDARD PLANS AND SPECIFICATIONS AND OTHER DOCUMENTS CALLED FOR IN SECTION 0-22.3 OF THE PROJECT MANUAL.



City of Seattle  
**Seattle Department of Transportation**

ORDINANCE NO. \_\_\_\_\_ APPROVED \_\_\_\_\_  
FUND: \_\_\_\_\_  
SCALE: H. 1"=20'V. INSPECTOR'S BOOK \_\_\_\_\_

**SOUTH SPOKANE STREET VIADUCT  
EASTBOUND 4TH AVENUE SOUTH  
OFF-RAMP**

PC	TS4047A
R/W	TS4047B
CO	TS4047C
VAULT PLAN NO.	782-273
SHEET	194 OF 219